

Wall Plates

Weatherproof Plates for Receptacles and Switches

Vertical, for FS/FD box mounting



HBL7423WO



HBL7425WOA



HBL7424WO



HBL7420



HBL7320



HBL3393


IP44
 SUITABILITY
For Receptacles With Face Diameters of 1.36"-1.39" (34.5-35.3)

Description	Catalog Numbers
Thermoplastic, WET LOCATIONS with cover "open," gray.	HBL7423WO
Thermoplastic, WET LOCATIONS with cover "open," yellow.	HBL74CM23WO
Cast aluminum, WET LOCATIONS with cover "closed."	HBL7420▲

For Receptacles With Face Diameters of 1.55"-1.58" (39.4-40.1)

Description	Catalog Numbers
Thermoplastic, WET LOCATIONS with cover "open," gray.	HBL7425WOA
Thermoplastic, WET LOCATIONS with cover "open," yellow.	HBL74CM25WOA
Cast aluminum, WET LOCATIONS with cover "closed."	HBL7420▲
Cast aluminum, no lift cover, NOT weatherproof.	HBL7320

For Receptacles With Face Diameters of 1.68"-1.72" (42.7-43.7)

Description	Catalog Numbers
Thermoplastic, WET LOCATIONS with cover "open," gray.	HBL7424WO
Thermoplastic, WET LOCATIONS with cover "open," yellow.	HBL74CM24WO
Cast aluminum, WET LOCATIONS with cover "closed."	HBL3393
Cast aluminum, no lift cover, NOT weatherproof.	HBL3394

▲ A fiber shield is furnished with HBL7420 plate. An effective means of weatherproofing toggle and lock type switches when this shield is used in combination with the plate.

All weatherproof lift cover plates on this page are listed by Underwriters Laboratories, Inc. as "WDL Closed" for use in wet locations with cover closed and in damp locations.

Weatherproof Covers For Single Receptacles On FS/FD Boxes

Note: All weatherproof plates are UL Listed for WET LOCATIONS WITH COVER CLOSED, for intermittent use in wet locations or use in damp locations. Those with suffix WO are listed for WET LOCATIONS with cover open in continuous use. All plates are gasketed and self-closing.

National Electrical Code**Receptacles in Damp or Wet Locations.**

(a) **Damp Locations.** A receptacle installed outdoors in a location protected from the weather or in other damp locations shall have an enclosure for the receptacle that is weatherproof when the receptacle is covered (attachment plug cap not inserted and receptacle covers closed).

An installation suitable for wet locations shall also be considered suitable for damp locations.

A receptacle shall be considered to be in a location protected from the weather where located under roofed open porches, canopies, marquees, and the like, and will not be subjected to a beating rain or water run-off.

(b) Wet Locations.

(1) A receptacle installed in a wet location where the product intended to be plugged into it is not attended while in use (e.g., sprinkler system controllers, landscape lighting, holiday lights, etc.) shall have an enclosure that is weatherproof with the attachment plug cap inserted or removed.

(2) A receptacle installed in a wet location where the product intended to be plugged into it will be attended while in use (e.g., portable tools, etc.) shall have an enclosure that is weatherproof when the attachment plug cap is removed.